

## Electrical Service for Festival Vendors

- All vendors will be provided one 20 amps 120 volt (1800 watts) circuit as a part of their basic site fee.
- Any additional electrical service will carry with it an additional fee in accordance with the fee schedule on your application. Additional service must be ordered and paid for in advance.
- If applicable, fill out the form below and include with your application. Applications without the correct information will not be considered.
- All electrical service connections will be provided to within 30 feet of the vendor space.
- Vendors are responsible for providing their own power cords and power distribution from the service connection to and within their vending space. A 20 amp 120 circuit requires a 12-gauge power cord. Use of 14 or 16 gauge is not acceptable.

For service other 20 amps 120 standard electrical plugs. Please specify the style of connector you're using the NEMA number or similar designation or with the exact writing on the plug and cable. See examples below:

NEMA 6-20	20 amps 240 volt
NEMA 14-50	50 amps 240 volt 4 wire range plug
NEMA L14-20	20 amps 120/240 twist lock
NEMA L6-20	20 amps 240-volt twist lock
NEMA L14-30	30 amps 120/240 twist lock
CS63-65C	50 amps 120/240 Cal. Std twist lock
Bare ends 6 gauge 4 conductor SO cable	

Connector Description: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_